

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1496:140 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Firecom, Inc. 39-27 59th Street, Woodside, NY 11377
Contact: Howard Kogen (718) 899-6100

DESIGN: Model RTI-1 remote trouble indicator and Model MP-300 end-of-line resistor. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Model RTI-1: 30 VDC, 1A
Model MP-300: 3.9 KOhm to 22 KOhm, 1W

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. Intended to be installed in standard outlet boxes and for indoor use only.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as control unit accessories for use with separately listed electrically and functionally compatible fire alarm control units.

XLF: 7300-1477:100

07-14-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **APRIL 22, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager